



CAMDEN-WYOMING SEWER & WATER AUTHORITY

P.O. BOX 405, CAMDEN-WYOMING, DE 19934

PHONE: 302/697-6372

FAX: 302/697-2735

Public Notice

Update Regarding Loss of Water Reported on April 21, 2019

On Sunday, April 21, 2019 at approximately 1:00 PM the CWSWA began receiving messages regarding calls from low water pressure to loss of water in our service area.

Our crew arrived on scene to find the system was knocked off line by a recent storm. Once this was found, the crew immediately began to restore water to the system.

Although water has been restored at this time, it may take another 2.5 to 3 days for water pressure to restore to normal pressure in the mains. This time frame is contingent on the demand for water while the system continues to rebuild pressure.

We do apologize for the inconveniences this has caused. If you continue to have low water pressure over the course of a few days please do not hesitate to contact the office.

Our after-hour emergency line is the same number as our main office. 1-302-697-6372.

If you have any questions please do not hesitate to contact us.

Respectfully,

The Camden-Wyoming Sewer and Water Authority.

Posted 4/22/19
